



Certificate of Conformity

LVD Certification No.: ATJC22060680003000S

Reference Report No. : ATJC22060680003000S

Applicant : Hangzhou Sugaomei Power Technology Co., Ltd

Address : No.29, Tushanba Road, Qianjiang Economic Development Area,
Yuhang, Hangzhou, China

Manufacturer : Hangzhou Sugaomei Power Technology Co., Ltd

Address : No.29, Tushanba Road, Qianjiang Economic Development Area,
Yuhang, Hangzhou, China

Product Description : Automatic Transfer Switch

Model No. : SUQ3-3200A, SUQ3-100A, SUQ3-160A, SUQ3-250A, SUQ3-400A,
SUQ3-630A, SUQ3-800A, SUQ3-1000A, SUQ3-1250A, SUQ3-1600A,
SUQ3-2000A, SUQ3-2500A, SGL1600/4

Rating(s) : AC400V, 50/60Hz, 100-3200A

Trademark : N/A

The above products have been tested by us with listed standards and found in compliance with the Directive 2014/35/EU. It is possible to use CE marking to demonstrate the compliance with this Directive.

Test Standards	: EN 60947-2:2017+A1:2020
----------------	---------------------------

The certificate is based on a single evaluation of tested samples of above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test laboratory logo.



Authorized Signer :



Shenzhen An-Teng Testing Service Co., Ltd

Floor 5, No. 11, Hebei Industrial Zone, Hualian Community, Longhua Street, Longhua District, Shenzhen, China.

Tel: 86-755-27724522 Fax: 86-755-27724533 Web: www.antenglab.com